

2M KABLO SAN. ve TIC. A.S.

Gaziosmanpasa OSB Mahallesi
4. Cadde No:18A 59500
Cerkezkoy – Tekirdag /TURKIYE
T: +90 (282) 758 35 00 (Pbx)
F: +90 (282) 758 35 10
E: info@2mkablo.com
www.2mkablo.com

DoP Number: 24TS03002.1

1 Identification Code of the Product-Types

Firekab RE-2X(St)HSWAH...CI

2 Intended Use/es

Cable for general applications in construction works subject to reaction to fire requirements

3 Manufacturer

2M Kablo San. ve Tic. A.S.
Gaziosmanpasa OSB Mahallesi 4. Cadde No:18A
59500 Cerkezkoy – Tekirdag /TURKIYE

4 Authorised Representative

-

5 System of AVCP

3

6 Harmonised Standard

EN 50575:2014 + A1: 2016

Notified Body

1783 Turkish Standards Institution (TSE)

Determination by the manufacturer of the product type on the basis of type testing, type calculation, tabulated values or descriptive documentation of the product and the factory production control carried out by manufacturer.

7 Declared Performance/s

Reaction to Fire : Eca

Dangerous Substances : No

8 Appropriate Technical Documentation and/or Specific Technical Documentation

-



Important Remarks

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and behalf of the manufacturer by:
Mustafa BILGE

2M KABLO SAN. ve TIC. A.S.

Gaziosmanpasa OSB Mahallesi
4. Cadde No:18A 59500
Cerkezkoy – Tekirdag /TURKIYE
mbilge@2mkablo.com

T: +90 (282) 758 35 00 (Pbx)

F: +90 (282) 758 35 10

Date: 06.03.2024

2MKABLO
2M KABLO SANAYI ve TICARET A.S.
GAZIOSMANPASA OSB MAH. 4. CAD. NO: 18A
CERKEZKÖY / TEKİRDAĞ
CERKEZKÖY V.D.: 001 062 9585