# LPCB®

www.redbooklive.com

## **Certificate of Product Approval**

Certificate Number: 711d

Issue: 04

PRE

### 2M KABLO SAN. VE TIC. A.S

Sancaktepe Mahallesi Klas Sokak No:8 34580 Silivri Istanbul Turkey

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) as detailed below:

#### **Products**

Cable Types as listed below: Firekab SFR FE 180 See Certificate Appendix for details

#### **Standards**

BS 7629-1:2008 BS 6387:2013 (CWZ) EN 50200:2006 (Class PH120) EN 50200:2006 Annex E (30 mins) BS 5839-1:2013 (Clause 26.2d Standard) BS 8519 (Clause 11) BS 5266-1 (Clause 8.2.2a) BS 5839-6 (Clause 16.2) BS 5839-8 (Clause 27.6)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damies Ward			23 September	23 September 2015	
Signed for LPCB			Date of First Issue	Date of First Issue	
LPCB B C C C C C C C C C C C C C	This certificate and appendix remain the subject to terms and conditions (for de To check the validity of this certificate <u>www.redbooklive.com/check</u> , scan the LPCB is part of BRE Global Ltd, Garsto T: +44 (0)333 321 8811 F: +44 (0)192	etails visit <u>www.redbooklive.com/te</u> and appendix please visit e QR tag or contact us. n, Watford, WD25 9XX		bre	



# LPCB®

### Appendix to Certificate No: 711d 2M KABLO SAN. VE TIC. A.S

#### Issue: 04

Product name					
FireKab SFR FE 180 711d/01					
Nominal csa of conductor (mm²)	Core Construction (excluding drain wire & earth)	BS 7629-1	BS 6387	EN 50200	EN 50200 Annex E
1.0	2, 3 & 4(1)	Complies <sup>(2)</sup>	CWZ	PH120	30min <sup>(3)</sup>
1.5	2, 3 & 4(1)	Complies <sup>(2)</sup>	CWZ	PH120	30min <sup>(3)</sup>
2.5	2, 3 & 4(1)	Complies <sup>(2)</sup>	CWZ	PH120	30min <sup>(3)</sup>

Product name						LPCB Ref. No.
FireKab SFR FE 180						711d/01
Nominal csa of conductor (mm²)	Core Construction (excluding drain wire & earth)	BS 8519 Clause 11	BS 5266-1 Clause 8.2.2a	BS 5839-6 Clause 16.2	BS 5839-8 Clause 27.6	BS 5839-1 Clause 26.2
1.0	2, 3 & 4(1)	Category 1 <sup>(7)</sup> (control cable)	Complies <sup>(6)</sup>	Standard <sup>(4)</sup>	Standard <sup>(5)</sup>	Standard <sup>(4)</sup>
1.5	2, 3 & 4(1)	Category 1 <sup>(7)</sup> (control cable)	Complies <sup>(6)</sup>	Standard <sup>(4)</sup>	Standard <sup>(5)</sup>	Standard <sup>(4)</sup>
2.5	2, 3 & 4(1)	Category 1 <sup>(7)</sup> (control cable)	Complies <sup>(6)</sup>	Standard <sup>(4)</sup>	Standard <sup>(5)</sup>	Standard <sup>(4)</sup>

#### Uo/U 300/500 V

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damies Ward Signed for LPCB	Damien Ward31 March 201Certification Scheme ManagerDate of Issue		23 September 2015 Date of First Issue	
U KAS PRODUCT CON CON CON CON CON CON CON CON CON CON	This certificate and appendix remain subject to terms and conditions (for To check the validity of this certificat <u>www.redbooklive.com/check</u> , scan ti LPCB is part of BRE Global Ltd, Garst T: +44 (0)333 321 8811 F: +44 (0)1	details visit <u>www.redbooklive.com</u> e and appendix please visit he QR tag or contact us. on, Watford, WD25 9XX		

80018

## LPCB®

### Appendix to Certificate No: 711d 2M KABLO SAN. VE TIC. A.S

#### Issue: 04

#### Notes:

- 1. Solid conductor only
- 2. In meeting the requirements of BS 7629-1:2008, the FireKab SFR FE 180 cables listed met the requirements for smoke density of EN 61034-2:2005, the fire resistance requirements of BS 6387:2013 Categories CWZ and achieved less than 0.5%HCl for the outer covering, tapes and insulation when tested in accordance with EN 60754-1:2014.
- 3. The duration of 30min when tested in accordance with EN 50200:2006 Annex E is achieved by 15min for the fire and mechanic shock phase and a further 15min for the fire mechanic shock and water phase.
- 4. The FireKab SFR FE 180 cables listed conform to BS 7629-1:2008 met Class PH120 when tested in accordance with EN 50200: 2006 and met the 30min duration when tested in accordance with EN 50200:2006 Annex E and hence met the requirements for a standard fire resistant cable as described in Clause 26.2 of BS 5839-1:2013 and Clause 16.2 of BS 5839-6: 2013
- When tested in accordance with EN 50200: 2006 (PH30) and 30min duration when tested in accordance with EN 50200:2006 Annex E the cable met the requirements for a standard fire resistant cable as described in Clause 27.6 of BS 5839-8:2013.
- 6. When the cable conforms to BS 7629-1 and when tested in accordance with EN 50200: 2006 (PH60) and 30min duration when tested in accordance with EN 50200:2006 Annex E the cable met the requirements of an emergency lighting cable with an inherently high resistance to attack by fire as described in Clause 8.2.2 (a) of BS 5266-1: 2011.
- When tested in accordance with EN 50200: 2006 (PH30) and 30min duration when tested in accordance with EN 50200:2006 Annex E the cable met the requirements for a Category 1, control cable as described in Clause 11 (1) of BS 8519:2010.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



© BRE Global Ltd, 2015