



TYPE APPROVAL CERTIFICATE
No. ELE261825XT/015

This is to certify that the product below is found to be in compliance with the applicable requirement of the RINA type approval system.

<i>Description</i>	ELECTRIC CABLES
<i>Type</i>	M2XSY 0.6/1 kV
<i>Applicant</i>	2M KABLO SAN. VE TIC. A.S. GAZIOSMANPASA OSB MAH., 4.CADDE, No.18A Tekirdag 59500 Cerkezkoy TURKEY
<i>Manufacturer</i>	2M KABLO SAN. VE TIC. A.S.
<i>Place of manufacture</i>	GAZIOSMANPASA OSB MAH., 4.CADDE, No.18A Tekirdag 59500 Cerkezkoy TURKEY
<i>Reference standards</i>	IEC 60092-353; IEC 60092-350

Issued in **ISTANBUL** on **September 12, 2025**. This Certificate is valid until **August 19, 2028**

Onur Cenk Yalcin

RINA Services S.p.A.



This certificate consists of this page and 1 enclosure



TYPE APPROVAL CERTIFICATE

No. ELE261825XT/015

Enclosure - Page 1 of 1

M2XSY 0.6/1 kV

Materials/Components

Shipboard power cables, flame retardant, for ships and off-shore units installation

Rated voltage: 0.6 / 1 kV

Maximum rated conductor temperature: + 90 °C

Type: M2XSY

Marking: 2MKABLO IEC 60092-353 M2XSY n x s(mm²) 0.6/1 kV IEC 60332-3-22 [METER MARK]

Construction

Conductor: Stranded annealed or tinned copper Class 2 or Class 5

Insulation: XLPE

Lay-Up: All cores as layers

Filler: PVC

Screen: Galvanized Steel Wire Braiding

Outer Sheath: PVC ST2

Number of Units: 1

Number of Units: 2 to 5

Number of Units: 6 to 37

Number of Units: 37 to 48

Number of Units: 60

Cross-sectional area of conductor: 1 to 300 mm²

Cross-sectional area of conductor: 1 to 240 mm²

Cross-sectional area of conductor: 1 to 4 mm²

Cross-sectional area of conductor: 1 to 2.5 mm²

Cross-sectional area of conductor: 1 and 1,5 mm²

Reference documents: Technical Specification No: 118-4/2011 (28/03/2012)

Reference Standards: IEC 60092-350; IEC 60092-353; IEC 60092-360; IEC 60332-3-22 (CAT-A); IEC 60332-1-2; IEC 60228; IEC 60811; IEC 60754-1; IEC 60754-2

ISTANBUL 12.09.2025

