



TYPE APPROVAL CERTIFICATE
No. ELE261825XT/002

This is to certify that the product below is found to be in compliance with the applicable requirement of the RINA type approval system.

<i>Description</i>	ELECTRIC CABLES
<i>Type</i>	FM2XACH 150/250 V
<i>Applicant</i>	2M KABLO SAN. VE TIC. A.S. GAZIOSMANPASA OSB MAH., 4.CADDE, No.18A Tekirdag 59500 Cerkezkoy TURKEY
<i>Manufacturer</i>	2M KABLO SAN. VE TIC. A.S.
<i>Place of manufacture</i>	GAZIOSMANPASA OSB MAH., 4.CADDE, No.18A Tekirdag 59500 Cerkezkoy TURKEY
<i>Reference standards</i>	IEC 60092-350; IEC 60092-376.

Issued in **ISTANBUL** on **September 12, 2025**. *This Certificate is valid until* **August 19, 2028**

Onur Cenk Yalcin

RINA Services S.p.A.



This certificate consists of this page and 1 enclosure



TYPE APPROVAL CERTIFICATE

No. ELE261825XT/002

Enclosure - Page 1 of 1

FM2XACH 150/250 V

Materials/Components

Shipboard instrumentation, control and communication cables, flame retardant, halogen free with low smoke emission, for ships and off-shore units installation.

Rated voltage: 150 / 250 V

Maximum rated conductor temperature: + 90 °C

Type: FM2XACH

Marking: 2MKABLO IEC 60092-376 FM2XACH n x m x s(mm2) 150/250 V IEC 60332-3-22 [METER MARK]

Construction

Conductor: Stranded annealed or tinned copper Class 2 or Class 5

Insulation: XLPE

Individual Shielding: AL-PES foil (with stranded tinned copper drain wire)

Lay-Up: Shielded pairs and quads are stranded in layers

Screen: Tinned or annealed copper wire braid

Outer Sheath: HFFR SHF1

Number of Elements : 1C to 37C Cross-sectional area of conductors 0,5 and 2.5 mm²
1P to 37P
1T to 12T
1Q to 12Q

Reference documents: Technical Specification No: 105-3/2011 (15/03/2012)

Reference Standards: IEC 60092-350; IEC 60092-376; IEC 60332-3-22; IEC 60332-1-2; IEC 60228; IEC 60811; IEC 60754-1; IEC 60754-2; IEC 60092-360; IEC 60684-2; IEC 61034-1/2; IEC60754-1/2

ISTANBUL 12.09.2025

