

TYPE APPROVAL CERTIFICATE

Certificate No: **TAE000015F**Revision No:

| This is to certify: | | | | | |
|---|--|--|--|--|--|
| That the Electric Pow | ver Cable | | | | |
| with type designation(s | 6) | | | | |
| Issued to 2M Kablo San TEKİRDAĞ, Turko | ayi ve Ticaret A.S ey | | | | |
| | ification – Ships, offshore units, and high speed and light craft ramme DNVGL-CP-0399 – Type approval – Electric cables | | | | |
| Application: | | | | | |
| Product approved by | this certificate is accepted for installation on all vessels classed by DNV. | | | | |
| Rated voltage (kV) Temp. class (°C) | 0,6/1 90 | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

Issued at Høvik on 2021-09-14

for DNV

This Certificate is valid until 2026-07-03.

DNV local station: Istanbul

Approval Engineer: Georgy Abramenko

Marta Alonso Pontes
Head of Section

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251 Revision: 2021-03 www.dnv.com Page 1 of 3

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-031245-10** Certificate No: **TAE000015F**

Revision No: 2

Product description

M2XH 0,6/1 kV

Construction:

Conductors: Plain annealed stranded copper class 2 or tinned copper class 5

Core insulation: XLPE

Inner sheath/ Halogen free filler or polyester tape

separator:

Outer sheath: SHF1

| No of Elements: | Cross sectional area [mm²] | | |
|------------------------------|---|--|--|
| 1 | 1,0 1,5 2,5 4 6 10 16 25 35 50 70 95 120 150 185 240 300 | | |
| 2, 3, 4 | 1,0 1,5 2,5 4 6 10 16 25 35 50 70 95 120 150 185 240 | | |
| 5, 7, 12, 16, 19, 24, 27, 37 | 1,0 1,5 2,5 | | |

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Data sheet: 2M Kablo datasheet ref. no. 0150-15, date 08.04.2015

Test reports: 2M Kablo test reports, ref. techdocs 24-32, received 03.06.2016, techdoc 19, received 04.09.2019

Statement of design description change dated 24.05.2021

Tests carried out

| Standard | Issued | General description | Limitation |
|----------------|------------|--|---------------------|
| IEC 60092-350 | 2014-08 | General construction and test methods of power, | |
| | | control and instrumentation cables for shipboard | |
| | | and offshore applications | |
| IEC 60092-360 | 2014-04 | Electrical installations in ships - Part 360: | |
| | | Insulating and sheathing materials for shipboard | |
| | | and offshore units, power, control, instrumentation | |
| | | and telecommunication cables. | |
| IEC 60092-353 | 2016-09 | Electrical installations in ships - Part 353: Power | |
| | | cables for rated voltages 1 kV and 3 kV | |
| IEC 60332-3-22 | 2018-07 | Tests on electric and optical fibre cables under | Bunch test |
| | | fire conditions – Part 3-22: Test for vertical flame | Category A |
| | | spread of vertically-mounted bunched wires or | |
| | | cables – Category A | |
| IEC 60332-1-2 | 2006-07 | Tests on electric cables under fire conditions. | |
| | | Test for vertical flame propagation for a single | |
| | | insulated wire or cable. | |
| IEC 60754-1 | 2011-11 | Test on gases evolved during combustion of | Low Halogen: |
| | | materials from cables – Determination of the | <0,5% Halogen |
| | | amount of halogen acid gas | |
| IEC 60754-2 | 2011-11 | Test on gases evolved during combustion of | Halogen free: |
| | | materials from cables – Determination of the | pH > 4,3 |
| | | degree of acidity of gases evolved during the | Conductivity < 10µS |
| | | combustion of materials taken from electric cables | |
| | | by measuring pH and conductivity | |
| IEC 61034-1/2 | 2013-07/09 | Measurement of smoke density of cables | Low smoke |
| | | burning under defined conditions – | |
| | | Test apparatus, procedure and requirements | |

Form code: TA 251 Revision: 2021-03 www.dnv.com Page 2 of 3



Job Id: **262.1-031245-10**Certificate No: **TAE000015F**

Revision No: 2

Marking of product

2M Kablo IEC 60092-353 - M2XH - 0,6/1 kV - IEC 60332-3-22 - meters - year.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE

Form code: TA 251 Revision: 2021-03 www.dnv.com Page 3 of 3