

Certificate No: TAE000015M Revision No:

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Low Voltage Cable

with type designation(s)

FireKab BFOI FE180, FireKab BFCI FE180

2M Kablo Sanayi ve Ticaret A.S TEKİRDAĞ, Turkey

is found to comply with

DNV GL rules for classification - Ships and offshore units DNV GL class programme DNVGL-CP-0399 - Type approval - Electric cables

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Rated voltage (V) Temp. class (°C) **Type**

FireKab BFOI FE180 250V 90 FireKab BFCI FE180 250V 90

Issued at Høvik on 2019-09-18

This Certificate is valid until 2021-07-03. for **DNV GL**

DNV GL local station: Istanbul

Approval Engineer: Georgy Abramenko

Trond Sjåvåg **Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

www.dnvgl.com

Page 1 of 3

Job Id: **262.1-031245-1** Certificate No: **TAE000015M**

Revision No: 1

Product description

BFOI / BFCI 250 V

Construction:

Conductors: Plain annealed stranded copper class 2 or tinned copper class 5

Core insulation: Mica tape + XLPE

Lay-Up Pairs/triples/quads are stranded in layers

Inner sheath/ separator: Halogen free filler or polyester tape Screen/ Armour: Copper wire braiding and drain wire

Outer sheath: SHF1

	No of Elements:	Cross sectional area [mm²]
Pairs	1 2 3 4 5 7 10 12 16 19 24 27 37	0,5 0,75 1 1,5 2,5
Triads	1 2 3 4 5 7 10	0,5 0,75 1 1,5 2,5
Quads	1 2 3 4 5 7	0,5 0,75 1 1,5 2,5

Application/Limitation

This cable is fire resistant according to IEC 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Tests carried out

Standard	Issued	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of	
		power, control and instrumentation cables	
		for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360:	
		Insulating and sheathing materials for	
		shipboard and offshore units, power,	
		control, instrumentation and	
		telecommunication cables.	
IEC 60092-376	2003-05	Cables for control and instrumentation	
		circuits 150/250 V (300 V)	
IEC 60331-21	1999-04	Fire resistance / Circuit integrity – Test for	Minimum 180 minutes
		electric cables under fire conditions-Circuit	flame application + 15
		integrity – Part 21	minutes cooling down
IEC 60331-1/2	2009-05	Fire resistance / Circuit integrity – Test for	
		method for fire with shock at temperature	
		of at least 830°C for cables rated up to and	
		including 0,6/1 kV	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables	Bunch test
		under fire conditions – Part 3-22: Test for	Category A
		vertical flame spread of vertically-mounted	
		bunched wires or cables – Category A	

Form code: TA 251 Revision: 2016-12 www.dnvgl.com Page 2 of 3

Job Id: 262.1-031245-1 Certificate No: TAE000015M

Revision No:

Standard	Issued	General description	Limitation
IEC 60332-1-2	2006-07	Tests on electric cables under fire	
		conditions.	
		Test for vertical flame propagation for a	
		single insulated wire or cable.	
IEC 60754-1	2011-11	Test on gases evolved during combustion of	Low Halogen:
		materials from cables – Determination of	<0,5% Halogen
		the amount of halogen acid gas	
IEC 60754-2	2011-11	Test on gases evolved during combustion of	Halogen free:
		materials from cables – Determination of	pH > 4,3
		the degree of acidity of gases evolved	Conductivity < 10µS
		during the combustion of materials taken	
		from electric cables by measuring pH and	
		conductivity	
IEC 61034-1/2	2013-	Measurement of smoke density of cables	Low smoke
	07/09	burning under defined conditions –	
		Test apparatus, procedure and	
		requirements	

Marking of product2M Kablo IEC 60092-376 - BFOI - 150/250 V - IEC 60332-3-22 - IEC 60331 - meters - year, or: 2M Kablo IEC 60092-376 - BFCI - 150/250 V - IEC 60332-3-22 - IEC 60331 - meters - year.

END OF CERTIFICATE

Form code: TA 251 Revision: 2016-12 www.dnvgl.com Page 3 of 3