

# TYPE APPROVAL CERTIFICATE

**This is to certify:****That the Low Voltage Cable**with type designation(s)  
**FireKab BFXI FE180**

Issued to

**2M Kablo Sanayi ve Ticaret A.S**  
**TEKİRDAĞ, Turkey**

is found to comply with

**DNV GL rules for classification – Ships and offshore units**  
**DNV GL class programme DNVGL-CP-0399 – Type approval – Electric cables****Application :****Product approved by this certificate is accepted for installation on all vessels classed by DNV GL.****Rated voltage (V) 250V**  
**Temp. class (°C) 90**Issued at **Høvik** on **2019-09-18**This Certificate is valid until **2021-07-03**.DNV GL local station: **Istanbul**Approval Engineer: **Georgy Abramenko**for **DNV GL**

---

**Trond Sjøvåg**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-031245-1**  
 Certificate No: **TAE000015S**  
 Revision No: **1**

## Product description

BFXI 250 V

Construction:

Conductors: Plain annealed stranded copper class 2 or tinned copper class 5  
 Core insulation: Mica tape + XLPE  
 Separator: Polyester tape  
 Outer sheath: SHF1

No of Elements:	Cross sectional area [mm <sup>2</sup> ]
2 3 4 5 7 10 12 14 16 19 24 27 37	0,75

## Application/Limitation

This cable is fire resistant according to IEC 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

## Type Approval documentation

### Tests carried out

Standard	Issued	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60092-376	2017-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60331-21	1999-04	Fire resistance / Circuit integrity – Test for electric cables under fire conditions–Circuit integrity – Part 21	Minimum 180 minutes flame application + 15 minutes cooling down
IEC 60331-1/2	2018-03	Fire resistance / Circuit integrity – Test for method for fire with shock at temperature of at least 830°C for cables rated up to and including 0,6/1 kV	
IEC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Bunch test Category A
IEC 60332-1-2	2006-07	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables – Determination of	Low Halogen: <0,5% Halogen

Job Id: **262.1-031245-1**  
Certificate No: **TAE000015S**  
Revision No: **1**

Standard	Issued	General description	Limitation
		the amount of halogen acid gas	
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables – Determination of the degree of acidity of gases evolved during the combustion of materials taken from electric cables by measuring pH and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS
IEC 61034-1/2	2013-07/09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke

### Marking of product

2M Kablo IEC 60092-376 – BFXI – 150/250 V – IEC 60332-3-22 – IEC 60331 – meters – year.

### Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.