

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Low Voltage Cable**with type designation(s)
BFXI (C) FM2XAH-FFR

Issued to

2M Kablo Sanayi ve Ticaret A.S
TEKİRDAĞ, Turkey

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft
DNV GL class programme DNVGL-CP-0399 – Type approval – Electric cables**Application :****Product approved by this certificate is accepted for installation on all vessels classed by DNV GL.****Rated voltage (V) 250****Temp. class (°C) 90**Issued at **Høvik** on **2019-09-18**This Certificate is valid until **2023-03-01**.DNV GL local station: **Istanbul**Approval Engineer: **Georgy Abramenko**for **DNV GL**

Trond Sjøvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-031245-1**
Certificate No: **TAE00002NJ**
Revision No: **1**

Product description

Type: BFXI (C) / FM2XAH-FFR 250 V

Construction:

Conductors: Plain or tinned, stranded copper according to IEC 60228 Class 5

Core insulation: Mica-tape + XLPE

Screen: AL-PES tape with tinned copper drain wire

Outer sheath: SHF1

Number of cores	Cross section
4	2x0,75 + 2x0,5

Application/Limitation

This cable is fire resistant in accordance with IEC Publication 60331-21.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation


Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-376	2017-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60331-21	1999-04	Tests for electric cables under fire conditions – Circuit integrity – Part 21: Procedures and requirements – Cables of rated voltage up to and including 0,6/1,0 kV	Minimum 180 min + 15 min cooling down time
IEC 60332-1-2	2018-03	Tests on electric and optical fibre cables under fire conditions – Part 1-1: Test for vertical flame propagation for a single insulated wire or cable – Apparatus	Flame retardant small scale
IEC 60332-3-21	2018-07	Tests on electric cables under fire conditions – Part 3-21: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A F/R	Bunch test Category A F/R
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2005-04	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

Marking of product

2M Kablo - 250 V - BFXI (C) / FM2XAH-FFR - 2x0,75+2x0,5 mm² - IEC 60092/376 - IEC 60331 - IEC 60332-1&3 DNV - LOTNO - Order No - meter - Marine Cable.

Periodical assessment



Job Id: **262.1-031245-1**
Certificate No: **TAE00002NJ**
Revision No: **1**

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE